

SPECIFICATIONS FOR REINFORCING CAGE

- 1) REINFORCING STEEL SHALL CONFORM TO THE REQUIREMENTS OF OF ASTM A615, GRADE 60, UNLESS OTHERWISE SHOWN.
- 2) REINFORCING CAGES FOR FOOTINGS SHALL BE ASSEMBLED WITH #3 CIRCULAR TIES SPACED AT 9" OR WITH ONE CONTINUOUS #3 SPIRAL TIE, AS SHOWN. ALL REINFORCING SHALL BE TIED USING APPROPRIATE WIRE, NOT WELDED, AND SHALL INCLUDE PLASTIC CENTRALIZERS AND CHAIRS ON VERTICAL BARS TO PROPERLY CENTER THE REINFORCING IN EACH DRILLED HOLE.

